

Summary of Compliance Report for the Year 2014-15 -Updated

SN	CPP Entity	Yearly									REMARK
		Consumption (MU)	Solar Obligation (MU) @ (0.75%)	Non Solar Obligation (MU) @ (6.00%)	Solar Power Procured/Generate (MU)	Solar REC Procured (MU)	Non Solar Power Procured (MU)	Non Solar REC Procured (MU)	Shortfall Solar Power Procured (MU) #	Shortfall Non Solar Power Procured (MU) #	
1	Ultratech Cement Ltd,Hirmi Cement Works,Baloda Bazar-Bhatapara	167.76	1.2582	10.0656	1.08141	0	0	10.017	0.17679	0.0486	Shortfall for Both Solar & Non-Solar Power .As per the submission by Ultratech Hirmi they have carry forwarded previous year excess Solar obligation of 0.195335 MU and Non Solar 0.002935 MU in 2014-15, Excess Solar Power 0.152985 MU of the year 2013-14 is only Considered.
2	Century Cement,Baikunth	149.2423	1.1193	8.9545	0.816211	0.304	0	8.954	-0.0009	0.0005	Comply for Solar & shortfall for Non-Solar
3	Ambuja Cement,Rawan	233.02	1.7477	13.9812	0.3497	2.844	0	12.536	-1.4461	1.4452	Comply for Solar & Shortfall for Non-Solar
4	Uniworth Limited	0.37255	0.0028	0.02235	0	0	0	0	0.0028	0.02235	Shortfall for Both Solar & Non-Solar Power
5	Nalwa Steel & Power	134.158	1.0062	8.0495	0	0	0	0	1.0062	8.0495	Shortfall for Both Solar & Non-Solar Power
6	ACB (INDIA) LIMITED	26.7262	0.2004	1.6036	0	0.201	0	1.61	-0.0006	-0.0064	Comply for Solar & Non-Solar Power
7	Spectrum Coal & Power Limited	9.78	0.0734	0.5868	0	0.072	0	0.582	0.0014	0.0048	Shortfall for Both Solar & Non-Solar Power
8	ACC Limited Jamul Cement	124.969	0.9373	7.4981	0	0.94	0	7.7	-0.0027	-0.2019	Comply for Both Solar & Non-Solar Power
9	Ultratech Cement Ltd,Rawan Cement Works, Rawan, Baloda Bazar-Bhatapara	243.522	1.8264	14.6113	0.84	0	0	14.665	0.9864	-0.0537	Shortfall for Solar & Comply for Non-Solar
10	Bhilai Steel Plant, Bhilai *	1624.11	12.1808	97.4466	0	0	330.646	0	12.1808	-233.1994	As per report they have compensated by CoGen Power

11	Madhya Bharat Paper	11.87	0.0890	0.7122	0	0	0	0	0.0890	0.7122	Shortfall for Both Solar & Non-Solar Power
12	Mahendra Sponge & Power LTD.	57.463	0.4310	3.44778	0	0	0	0	0.4310	3.44778	Shortfall for Both Solar & Non-Solar Power
13	DROLIA ELECTROSTEELS PVT.LTD.*	47.379	0.3553	2.8427	0.2256	0	23.364	0	0.1297	-20.5213	Shortfall for Solar & Comply for Non-Solar
14	G.R.SPONGE & POWER LIMITED*	34.891	0.2617	2.0935	0	0	0	0	0.2617	2.0935	Shortfall for both Solar & Non-Solar Power
15	S.K.SARAWAGI & CO. (P) LTD*	12.76	0.0957	0.7656	0.0000	0	0	0	0.0957	0.7656	Shortfall for Both Solar & Non-Solar Power
16	Shivalay Ispat & Power Pvt. Ltd.	11.267	0.0845	0.6760	0.101	0	0	0	-0.0165	0.6760	Comply for Solar & Shortfall for Non-Solar
17	BHAGWATI POWER & STEEL LTD.	11.9010	0.0893	0.7141	0.076585	0	0	0	0.0127	0.7141	Shortfall for Both Solar & Non-Solar Power
18	Real Ispat & Power Ltd.	130.2396	0.9768	7.8144	0.0548	0	0	0	0.9220	7.8144	Shortfall for Both Solar & Non-Solar Power
19	API ISPAT & POWERTECH (P) LTD.	26.719	0.2004	1.6031	0	0	0	0	0.2004	1.6031	Shortfall for Both Solar & Non-Solar Power
20	JINDAL STEEL & POWER LIMITED*	2559.02	19.1927	153.5412	0	0	1203.37	0	19.1927	-1049.8288	Shortfall for Solar & Comply for Non-Solar
21	SUNIL SPONGE PVT. LTD.	16.4911	0.1237	0.9895	0	0	0	0	0.1237	0.9895	Shortfall for Both Solar & Non-Solar Power
22	GODAWARI POWER & ISPAT	214.71	1.6103	12.8826	0	0	0	0	1.6103	12.8826	Shortfall for Both Solar & Non-Solar Power
23	LAFARGE INDIA (P)LTD. SONADIH	0.1700	0.0013	0.0102	0	0.0020	0	0.0100	-0.0007	0.0002	Comply for Solar & Shortfall for Non-Solar
24	LAFARGE INDIA (P)LTD. ARASMETA	0	0	0	0	0	0	0.37	0	-0.3700	Consumption is Nil for 2014-15 (0.37 MU Non Solar Carry Forward from prev. year)
25	HI-TECH POWER & STEEL LIMITED *	38.3605	0.2877	2.3016	0.224062	0	0	0	0.0636	2.3016	Shortfall for both Solar & Non-Solar

* Non Solar Obligation fulfilled by Waste Heat Recovery Based power.

-ve indicates Excess and +ve indicates Shortfall.